

2020 PIPELINE EMERGENCY QUICK REFERENCE GUIDE - IPA

EMERGENCY CONTACT LIST

Company Name	Emergency Number
Alliance Pipeline	1-800-884-8811
Alliant Energy - Interstate Power and Light	1-319-365-8040
Archer Daniels Midland Company (ADM).....	1-563-242-1121
Black Hills Energy.....	1-800-694-8989
BP Pipelines (North America), Inc.	1-800-548-6482
Buckeye Partners, L.P.	1-866-514-8380
Cedar Fall Utilities	1-319-268-5340
Central Iowa Power Cooperative (CIPCO).....	1-866-782-5518
City of Waukee	1-515-249-1212
Dakota Access Pipeline (DAPL)	1-800-753-5531
Enterprise Products Operating, LLC.....	1-888-883-6308
Flint Hills Resources	1-800-688-7594
Harlan Municipal Utilities	1-712-755-5182
Kinder Morgan / Natural Gas Pipeline Company of America.....	1-800-733-2490
Liberty Utilities	1-855-644-8134
Magellan Midstream Partners, L.P.....	1-800-720-2417
MidAmerican Energy Company.....	1-800-275-5743
Northern Natural Gas Company	1-888-367-6671
NuStar Pipeline Operating Partnership L.P.	1-800-759-0033
ONEOK North System, LLC	1-888-844-5658
Pembina Cochin LLC.....	1-800-265-6000
Sinclair Transportation Inc.	1-800-321-3994
TC Energy / ANR Pipeline Company.....	1-800-447-8066
TC Energy / Northern Border Pipeline Company	1-800-447-8066
Traer Municipal Utilities	1-319-478-2525
Woodbine Municipal Utilities.....	1-712-644-2537

To learn more about your local pipeline operators, please visit ia.pipeline-awareness.com

Note: The above numbers are for emergency situations. Additional pipeline operators/companies may exist in your area. Visit the National Pipeline Mapping System at www.npms.phmsa.dot.gov for transmission companies not listed above.

One-Call System	Phone Number
Iowa One Call	1-800-292-8989 or 811

2020 PIPELINE EMERGENCY QUICK REFERENCE GUIDE - IPA

INCIDENT RESPONSE

- Always approach from upwind/park vehicle a safe distance away/if vehicle stalls – DO NOT attempt to restart
- Gather information/establish incident command/identify command structure
- Initiate communications with pipeline/gas company representative ASAP
- Control/deny entry: vehicle, boat, train, aircraft, foot traffic, media – refer all media questions to pipeline/gas representatives

RISK CONSIDERATIONS

- Type/volume/pressure/location/geography of product
- Environmental factors – wind, fog, temperature, humidity
- Sight, sound, smell – indicators vary depending on product
- Black, dark brown or clear liquids/dirt blowing into air/peculiar odors/dead insects around gas line/dead vegetation
- Rainbow sheen on the water/mud or water bubbling up/frozen area on ground/frozen area around gas meter
- Other utility emergencies

PIPELINE MARKERS

The U.S. Department of Transportation (DOT) requires the use of signs to indicate the location of underground pipelines. Markers like these are located on road, railroad, and navigable waterway crossings. Markers are also posted along the pipeline right-of-way. Markers may not be located directly over the pipeline it marks.

The markers display:

- The product transported
- The name of the pipeline operator
- The operator's emergency number



PRODUCT HAZARDS AND CHARACTERISTICS

Petroleum (flow rate can be hundreds of thousands of gallons per hour) **TYPE 1**

- Flammable range may be found anywhere within the hot zone
- H2S can be a by-product of crude oil

Type 1 Products	Flash Point	Ignition Temperature
Gasoline	- 45 °F	600 °F
Jet Fuel	100 °F	410 °F
Kerosene	120 °F	425 °F
Diesel Fuel	155 °F	varies
Crude Oil	25 °F	varies

Natural Gas (flow rate can be hundreds of thousands of cubic feet per hour) **TYPE 2**

- Flammable range may be found anywhere within the hot zone between 4% and 15%
- Rises and dissipates relatively quickly
- H2S can be a by-product of natural gas – PPM = PARTS PER MILLION
 - 0.02 PPM Odor threshold
 - 10.0 PPM Eye irritation
 - 100 PPM Headache, dizziness, coughing, vomiting
 - 200-300 PPM Respiratory inflammation within 1 hour of exposure
 - 500-700 PPM Loss of consciousness/possible death in 30-60 min.
 - 700-900 PPM Rapid loss of consciousness; death possible
 - Over 1000 PPM Unconsciousness in seconds; death in minutes

- Incomplete combustion of natural gas may release carbon monoxide
- Storage facilities may be present around populated areas/ can be depleted production facilities or underground caverns
- Gas travel may be outside the containment vessel along the natural space between the pipe and soil
- Lower/Upper Explosive Limit depends on characteristics of gas (SDS)

Propane, Butane and Other Similar Products - **TYPE 3** (*e.g. Carbon Dioxide / Anhydrous Ammonia)

- Flammable range may be found anywhere within the hot zone
- Products cool rapidly to sub-zero temperatures once outside the containment vessel
- Vapor clouds may be white or clear

Type 3 Products	Flash Point	Ignition Temperature
Propane	- 150 °F	920-1120 °F
Butane	- 60 °F	725-850 °F
Anhydrous Ammonia	- 51 °F	1204-1560 °F

- * Caustic - Can freeze/burn skin
- * Expands Rapidly
- * Liquid to a fog gas state!

